

PH: 0475 2221151

E-mail - jicameenadplr@gmail.com



QUALITY CONTROL SUB DISTRICT LABORATORY

KERALA WATER AUTHORITY

JICA WTP MEENAD THOLICODU.P.O, PUNALUR KOLLAM - 691333

REPORT ON ANALYSIS OF WATER


Report No - 2025/QCSDL/JICA/758.			Date:- 24.03.2025	
THE PRINCIPAL, PUSHPAGIRI SENIOR SECONDARY SCHOOL, EDAMON. Pin - 691307. PH.9645764101.			1. Date of Receipt : 21.03.2025.	
			2. Sampling done by:- CUSTOMER	
			3. Sample Code : 2025/QCSDL/JICA/758.	
			4. Source of Sample : Open Well Water	
			5. Sample Description : Drinking Water	
			6. Sample Quantity : 250 ml.	
			7. Sample Condition : Good.	
			8. Test Performing Dates From : 21.03.2025 To : 24.03.2025	
Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms/ 100 ml	Shall not be detected/100 ml	IS 15185 : 2016 (Reaffirmed 2021)	ABSENT
2	E. coli/100 ml	Shall not be detected/100 ml	IS 15185 : 2016 (Reaffirmed 2021)	ABSENT

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

* End of Report *	Authorized By Bacteriologist
--------------------------	-------------------------------------

KWA/QCSDL/JICA/R/19 Issue No. 01 Issue Date: 04.01.2024 Rev. No. 01 Rev Date: 01/01/2025

Page 1 of 1



BACTERIOLOGIST
QUALITY CONTROL SUB DISTRICT LAB
JICA WTP MEENAD
KERALA WATER AUTHORITY
PUNALUR